

Building linear parameter varying models using adaptation, for the control of a class of nonlinear systems

Coşku KASNAKOĞLU

*Department of Electrical and Electronics Engineering
TOBB University of Economics and Technology, 06560 Ankara-TURKEY
e-mail: kasnakoglu@etu.edu.tr*

Abstract

In this paper a novel method is proposed for constructing linear parameter varying (LPV) system models through adaptation. For a class of nonlinear systems, an LPV model is built using its linear part, and its coefficients are considered as time-varying parameters. The variation in time is controlled by an adaptation scheme with the goal of keeping the trajectories of the LPV system close to those of the original nonlinear system. Using the LPV model as a surrogate, a dynamical controller is built by utilizing self-scheduling methods for LPV systems, and it is shown that this controller will indeed stabilize the original nonlinear system.

Key Words: *Linear parameter varying (LPV) systems, nonlinear systems, adaptive systems, self-scheduling.*

1. Introduction

Linear parameter-varying (LPV) systems are an important class of dynamical systems, where the system model has a linear structure, but it is dependent on one or more parameters that are time-varying. An LPV system therefore represents a family of linear time varying (LTV) systems, one for each parameter trajectory [1]. LPV models can also be interpreted as a weighted combination of linear models, where the weights are the elements of the parameter vector. With this interpretation, one can also utilize LPV models to provide continuous local estimates of LTI models [2]. Since having one LPV model is much more compact than keeping an array of LTI models at different operating points, LPV models are of high interest for industrial applications where gain-scheduling approaches are common practice [3, 4, 5]. An additional benefit offered by LPV systems is the availability of systematic and robust controller design methods that can cope with arbitrary fast variations of the parameter vector [6, 7, 1]. Control designs based on LPV models have enjoyed a fair amount of success in the control of aircrafts [8, 9], missiles [10, 6], land vehicles [11], engines [12, 13], power plant processes [14] and fluid flow problems [15, 16].

Despite their usefulness, it is difficult to build LPV models in the first place, and methods to obtain such models is a field of active research. Typically one collects input, output and parameter trajectory data, and

utilizes LPV system identification methods, among which one can list linear fractional transformations [17], subspace identification methods [18, 19], least mean square and recursive least-squares algorithms [20] and prediction error methods [9].

In this work we develop a novel and alternative method for building LPV system models, where the main idea is to start with a nonlinear dynamical model describing the system, and approximate this system with an LPV model whose parameter trajectories are generated by an adaptation scheme. For many real-life processes, considerable effort has already been devoted to their mathematical modeling, as a result of which there exist accurate nonlinear models readily available for these processes. While these models can describe the dynamics with considerable accuracy, their high complexity makes controller design extremely difficult. Obtaining an LPV model to approximate these models enables the use of the systematic controller design tools developed for LPV systems [6, 7, 1]. In this paper an LPV system is built from the linear portion of the original nonlinear system dynamics and its coefficients are regarded as parameters. An adaptation scheme is constructed to modify the parameters in time so that the response of the LPV system matches that of the original nonlinear system. A controller is designed using self-scheduled robust design approaches available for LPV systems and using results from adaptive and nonlinear control theories [21, 22, 23, 24, 25, 26], it is shown that this controller will indeed stabilize the original nonlinear dynamics.

2. Motivation

Prior to proceeding with the details, a few comments on the motivations behind the approach in the paper are in order. This section aims solely at explaining the ideas in an informal manner and thus the discussion is kept brief and non-rigorous. The formal definitions and technical details will be provided starting from the next section (Section 3).

The first point to note is that an LPV system is actually quite different from an LTI system, in the sense that it allows the system matrices to vary with time. This enables the LPV system to produce a different linear system at each time instant, which means that it has the capability to produce an infinite number of systems. The task for each of these linear systems is to approximate the nonlinear system for an infinitesimal time interval.

As a simple example we may consider a one-dimensional autonomous nonlinear system Σ_N represented by the dynamics $\Sigma_N : \dot{x} = f(x)$. Suppose that at time t_1 the value of the system state is $x_1 = x(t_1)$. About the operating point x_1 this system can be approximated by a linear system $\Sigma_{L1} : \dot{x} = m_1x$ for some $m_1 \in \mathbb{R}$. Similarly let the system state at t_2 be $x_2 = x(t_2)$ and the state at t_3 be $x_3 = x(t_3)$. The system about x_2 and x_3 can be approximated by systems $\Sigma_{L2} : \dot{x} = m_2x$ and $\Sigma_{L3} : \dot{x} = m_3x$ for some $m_2, m_3 \in \mathbb{R}$. To generalize let the system state at time t be $x(t)$. Then the system about $x(t)$ can be approximated by $\bar{\Sigma}_L : \dot{x} = m(t)x$ which is an LPV system. The parameter m is to be modified at every time instant so as to keep the trajectories of $\bar{\Sigma}_L$ close to Σ_N at all times. The procedure described is illustrated in Figure 1.

This example is undoubtedly very simplistic, and in practice systems will be much more complicated. It is therefore necessary to build a formal and systematic approach, which will be carried out in the rest of the paper.

3. Problem description

In this paper we consider nonlinear dynamical systems of the form

$$\dot{x} = Lx + L_{in}u + \Phi_N(x, u) \quad (1)$$




Figure 1. The motivation for approximating a nonlinear system with an LPV system.

where $x \in \mathbb{R}^n$, $u \in \mathbb{R}^m$, $L \in \mathbb{R}^{n \times n}$, $L_{\text{in}} \in \mathbb{R}^{n \times m}$, and $\Phi_N : \mathbb{R}^n \times \mathbb{R}^m \rightarrow \mathbb{R}^n$. The function Φ_N vanishes at $(x, u) = (0, 0)$ together with its first derivatives, and satisfies a Lipschitz condition of the form

$$\exists k_N \in \mathbb{R}_+ \text{ such that } \|\Phi_N(x, u)\| \leq k_N \|\text{col}(x, u)\| \quad \forall x, u \quad (2)$$

where $\|\cdot\|$ is the Euclidian norm and col stands for column vector, i.e.

$$\text{col}(v_1, v_2, \dots, v_n) = [v_1^T \ v_2^T \ \dots \ v_n^T]^T .$$

The first task is to design a linear parameter varying (LPV) system

$$\dot{\hat{x}}(t) = \hat{L}(t)\hat{x}(t) + \hat{L}_{\text{in}}(t)u(t) + \hat{L}_{\text{err}}(t)(\hat{x}(t) - x(t)) \quad (3)$$

which closely represents the system in (1); that is, if $e := \hat{x} - x$, then e should remain bounded and small as $t \rightarrow \infty$. The second task is to design a controller for this system that achieves the stabilization of the system, as well as keeping the effect of the disturbance caused by the error e within reasonable limits. In addition, it is necessary to show that this controller will succeed in stabilizing the original system (1). The next section (Section 4) will be concerned with these two tasks.

4. LPV modelling and control design

In this section an LPV system of the form (3) is built to approximate the nonlinear system (1). Let us first build the parameter vector $\theta_L \in \mathbb{R}^p$ as

$$\theta_L := \text{col}(L(\cdot), L_{\text{in}}(\cdot)) \quad (4)$$

where $L(\cdot)$ denotes the column vector formed by stacking all elements of L on top of each other, i.e.

$$L(\cdot) := \text{col}(L_{11}, L_{21}, \dots, L_{n1}, \dots, L_{n1}, L_{n2}, \dots, L_{nn}) . \quad (5)$$

The column vector $L_{\text{in}}(\cdot)$ is defined similarly, and p is the total number of coefficients in L and L_{in} . Let us also define $\Phi_L \in \mathbb{R}^n \times \mathbb{R}^m$ to satisfy the expression

$$\Phi_L(x, u)\theta_L = Lx + L_{\text{in}}u . \quad (6)$$

In other words, $\Phi(x, u)$ is a $n \times p$ dimensional matrix with elements $\{\Phi_L(x, u)_{ij} \mid i = 1, \dots, n, j = 1, \dots, p\}$ where $\Phi_L(x, \gamma)_{ij}$ denotes the element at row i and column j . For instance, it is clear from (4) that the second parameter of θ_L is the second parameter of L , which is seen to be L_{21} from (5). Also, the second element of the state vector $x = \text{col}(x_1, x_2, x_3, \dots, x_n)$ is x_2 . Then from (6), it is clear that $\Phi_L(x, u)_{22} = x_1$. Other elements of $\Phi_L(x, u)$ can be constructed similarly. For future reference we also note that

$$\|\Phi_L(x, u)\theta_L\| \leq \|L\|\|x\| + \|L_{\text{in}}\|\|u\| \leq k_L\|\text{col}(x, u)\| \quad (7)$$

where $k_L := 2 \max\{\|L\|, \|L_{\text{in}}\|\}$. With the definition of $\Phi_L(x, u)$ as above, the LPV model sought can be written as

$$\dot{\hat{x}} = \Phi_L(x, u)\hat{\theta}_L - ke = \hat{L}x + \hat{L}_{\text{in}}u - ke \quad (8)$$

whose parameter vector $\hat{\theta}_L$ will be modified by an adaptation mechanism so that the state trajectory of (8) matches that of the nonlinear system (1). It should be emphasized that it is not the goal to achieve $\hat{\theta}_L \rightarrow \theta_L$; this is in fact undesirable, since it would imply that (8) approximates the behavior of (1) around only the origin $x = 0$. We would instead like θ_L to be modified to force the state trajectory of (8) to that of (1). In other words, the goal is to minimize the error $e = \hat{x} - x$, which is governed by the following dynamics ¹

$$\dot{e} = \dot{\hat{x}} - \dot{x} = \Phi_L(x, u)\hat{\theta}_L - ke - \Phi_L(x, u)\theta_L - \Phi_N(x, u) . \quad (9)$$

The adaptation mechanism considered for this purpose is of the following form

$$\dot{\hat{\theta}}_L = -k_t\Phi_L^T(x, u)e - k_t\Psi(e, \tilde{\theta}_L, x, u) \quad (10)$$

where $\tilde{\theta}_L := \hat{\theta}_L - \theta_c$, the function Ψ is defined as

$$\Psi(e, \tilde{\theta}_L, x, u) := \begin{cases} 0, & \|\text{col}(e, \tilde{\theta}_L)\| < k_x\|\text{col}(x, u)\|; \\ k_d\tilde{\theta}_L, & \|\text{col}(e, \tilde{\theta}_L)\| \geq k_x\|\text{col}(x, u)\| \end{cases} \quad (11)$$

and $k, k_t, k_d \in \mathbb{R}_+$, $\theta_c \in \mathbb{R}^p$ are constants to be selected as part of the design process. We also note the following for future reference: If L_c and $L_{c,\text{in}}$ are the matrices whose coefficients form θ_c , i.e. $\theta_c = \text{col}(L_c(\cdot), L_{c,\text{in}}(\cdot))$, then it holds that

$$\|\Phi_L(x, u)\theta_c\| \leq \|L_c\|\|x\| + \|L_{c,\text{in}}\|\|u\| \leq k_c\|\text{col}(x, u)\| \quad (12)$$

where $k_c := 2 \max\{\|L_c\|, \|L_{c,\text{in}}\|\}$. It can be shown that, by using the adaptation mechanism (10) with properly selected values for its constants, the error $e = \hat{x} - x$ can be made to remain bounded and small. This means that the state trajectories of the system (8) will approach those of the nonlinear system (1). The proof of this statement is postponed until Theorem 2; however we note that if this is the case, then the following interpretation can be made: Let us rearrange (8) as

$$\begin{aligned} \dot{\hat{x}} &= \hat{L}x + \hat{L}_{\text{in}}u - ke \\ &= \hat{L}(\hat{x} - e) + \hat{L}_{\text{in}}u - ke \\ &= \hat{L}\hat{x} + \hat{L}_{\text{in}}u + \hat{L}_{\text{err}}e . \end{aligned} \quad (13)$$

where $\hat{L}_{\text{err}} = -(\hat{L} + kI)$. One can then observe that (13) is of the same form as (3). Thus, if the signal e is bounded and small, one can regard system (8) as a linear parameter-varying system that approximates the original system, with the signal e entering as an external disturbance.

¹The system (8) can also be thought of as an adaptive psuedo-observer; the prefix *psuedo* is due to the fact that a real observer reconstructs the states from outputs, which is not the case here.

Remark 4.1 *At this point it will be useful to emphasize that θ_L , which encapsulates the parameters of the original system contained in L and L_{in} , is fixed and not time varying. What is time varying are the parameters of the LPV model, denoted by $\hat{\theta}_L$. These are the parameters that are modified by adaptation scheme (10) for the purpose of matching the trajectories of the LPV model (8) with those of the nonlinear system (1).*

The next task is to design a controller for this model to stabilize the system and also limit the effect of the error term on the dynamics. We will design a controller that can achieve these goals based on a robust automatic scheduling method [6, 7, 1], a brief summary of which is provided below.

Consider the following affine linear parameter dependent plant

$$\dot{x} = A(\theta)x + B_1(\theta)w + B_2u \quad (14)$$

$$z = C_1(\theta)x + D_{11}(\theta)w + D_{12}u \quad (15)$$

$$y = C_2x + D_{21}w \quad (16)$$

where x is the state, u is the control input, w is the disturbance input, y is the signal available for control, and z is the output to be controlled. The parameter vector θ is available in real-time and varies in a *polytope* Θ of vertices $\theta_1, \dots, \theta_p$; i.e. $\theta \in \Theta$ where $\Theta := \text{Co}\{\theta_1, \dots, \theta_p\} := \{\sum_{i=1}^p \alpha_i \theta_i : \alpha_i \geq 0, \sum_{i=1}^p \alpha_i = 1\}$ and Co stands for convex hull. We assume that $(A(\theta), B_2)$ is quadratically stabilizable over θ and $(A(\theta), C_2)$ is quadratically detectable over θ . The goal is to design a dynamic controller whose input is y and generates u which stabilizes the system (14)-(16) while minimizing the gain from w to z . For this purpose a linear parameter dependent controller having the following structure is considered

$$\dot{\zeta} = A_K(\theta)\zeta + B_K(\theta)y \quad (17)$$

$$u = C_K(\theta)\zeta + D_K(\theta)y \quad (18)$$

using which the feedback structure shown in Figure 2 is built.




Figure 2. Feedback structure for linear parameter varying control design.

The dynamics for this structure can be expressed as

$$\dot{x} = A_{cl}(\theta)x + B_{cl}(\theta)w \quad (19)$$

$$z = C_{cl}(\theta)x + D_{cl}(\theta)w \quad (20)$$

where A_{cl} , B_{cl} , C_{cl} and D_{cl} are the state-space matrices of the closed-loop system. The task is to design the controller matrices $A_K(\theta)$, $B_K(\theta)$, $C_K(\theta)$ and $D_K(\theta)$ so as to stabilize the closed loop system (19)-(20) while at the same time achieving $\|z\|_2 < \gamma\|w\|_2$ for some $\gamma \in \mathbb{R}_+$ for all permissible parameter trajectories

$\theta(t)$. The last item is important since the parameters will be generated by a separate adaptation system as in (8)-(10), which is treated as an exogenous system for control design purposes. The controller must therefore be able to account for all possible parameter trajectories within certain bounds, and achieve the stabilization and disturbance attenuation goal for all permissible cases. To design this controller we utilize the results summarized in the theorem below.

Theorem 1 Consider the LPV system in (14)-(16) and the dynamic controller structure given in (17)-(18). Let the controller matrices $A_K(\theta)$, $B_K(\theta)$, $C_K(\theta)$ and $D_K(\theta)$ be chosen in the following way:

1. Find a matrix $X_{cl} = X_{cl}^T > 0$, and controller matrices A_{K_i} , B_{K_i} , C_{K_i} , D_{K_i} for $k = 1 \dots p$ satisfying the following p LMIs

$$\begin{bmatrix} A_{cl}(\theta_i)^T X_{cl} + X_{cl} A_{cl}(\theta_i) & X_{cl} B_{cl}(\theta_i) & C_{cl}^T(\theta_i) \\ B_{cl}^T(\theta_i) X_{cl} & -\gamma I & D_{cl}^T(\theta_i) \\ C_{cl}(\theta_i) & D_{cl}(\theta_i) & -\gamma I \end{bmatrix} < 0 \quad \text{for } i = 1 \dots p. \quad (21)$$

2. For a given value of θ , compute the matrices $A_K(\theta)$, $B_K(\theta)$, $C_K(\theta)$ and $D_K(\theta)$ defining the LPV controller as

$$\begin{bmatrix} A_K(\theta) & B_K(\theta) \\ C_K(\theta) & D_K(\theta) \end{bmatrix} = \sum_{i=1}^p \alpha_i(\theta) \begin{bmatrix} A_{K_i} & B_{K_i} \\ C_{K_i} & D_{K_i} \end{bmatrix}$$

where $\alpha = (\alpha_1, \dots, \alpha_p)$ is a convex decomposition of θ such that $\theta = \sum_{i=1}^p \alpha_i \theta_i$ and $\sum_{i=1}^p \alpha_i = 1$.

Then, the closed loop system in Figure 2 is stable, with the stability established by the function $V_a(x_a) = x_a^T X_{cl} x_a$, where x_a is the system state. Moreover, it holds that $\|z\|_2 < \gamma \|w\|_2$.

Proof See [6]. □

For the problem at hand, the system to be controlled is given in (13), where the input to the controller is taken to be $y = x = \hat{x} - e$, and the system output is taken to be the $z = \text{col}(x, u) = \text{col}(\hat{x} - e, u)$. The system as such is rewritten below for later reference

$$\dot{\hat{x}} = \hat{L}(\hat{\theta}_L) \hat{x} - \left(\hat{L}(\hat{\theta}_L) + kI \right) e + \hat{L}_{in}(\hat{\theta}_L) u \quad (22)$$

$$z = \begin{bmatrix} I \\ 0 \end{bmatrix} \hat{x} - \begin{bmatrix} I \\ 0 \end{bmatrix} e + \begin{bmatrix} 0 \\ 1 \end{bmatrix} u \quad (23)$$

$$y = \hat{x} - e \quad (24)$$

where the dependence of \hat{L} and \hat{L}_{in} on the parameters $\hat{\theta}_L$ have been shown explicitly. The goal is to design a controller of the form (17)-(18), that will stabilize the system and also minimize the effect of the error to the system, for all permissible parameter trajectories $\hat{\theta}_L(t)$. Since the parameters $\hat{\theta}_L$ come from the adaptation mechanism (10), they are available in real-time and therefore can be used for the automatic scheduling of the controller. The control design however, is not a straightforward application of Theorem 1 above, since in (22), the input vector u enters the dynamics through a coefficient $\hat{L}_{in}(\hat{\theta}_L)$, which is dependent on the parameter vector $\hat{\theta}_L$. This prevents one from using Theorem 1 directly since the coefficient of the input, indicated as B_2 in (14), is assumed to be constant. The issue can be resolved by adding a known input filter to the system as

follows

$$\dot{\xi} = A_u \xi + B_u v \quad (25)$$

$$u = C_u \xi \quad (26)$$

where ξ is the filter state and v is the filter input, which will be considered as the control input from this point on. Hence, if we augment the system (22)-(24) with this filter we get

$$\begin{bmatrix} \dot{\hat{x}} \\ \dot{\xi} \end{bmatrix} = \begin{bmatrix} \hat{L}(\hat{\theta}_L) & \hat{L}_{in}(\hat{\theta}_L)C_u \\ 0 & A_u \end{bmatrix} \begin{bmatrix} \hat{x} \\ \xi \end{bmatrix} - \begin{bmatrix} \hat{L}(\hat{\theta}_L) + kI \\ 0 \end{bmatrix} e + \begin{bmatrix} 0 \\ B_u \end{bmatrix} v \quad (27)$$

$$z = \begin{bmatrix} I & 0 \\ 0 & C_u \end{bmatrix} \begin{bmatrix} \hat{x} \\ \xi \end{bmatrix} - \begin{bmatrix} I \\ 0 \end{bmatrix} e \quad (28)$$

$$y = [I \ 0] \begin{bmatrix} \hat{x} \\ \xi \end{bmatrix} - e. \quad (29)$$

In the augmented system (27)-(29), the coefficient of the input v is not dependent on the parameter vector $\hat{\theta}_L$. Thus, it is now possible to design an LPV controller that is automatically scheduled based on the parameter vector $\hat{\theta}_L$, through the procedure given in Theorem 1. Figure 3 shows a block diagram of the entire system including the nonlinear system, the input filter, the adaptation mechanism, and the controller.




Figure 3. Block diagram of the entire system.

5. Convergence and stability analysis

The following theorem justifies the validity of the approach considered, by proving that 1) the adaptation scheme will force the LPV system state trajectories to converge to the state trajectories of the original nonlinear system, and 2) the LPV controller designed for this LPV system will also stabilize the original nonlinear system.

Theorem 2 Consider the LPV plant augmented with an input filter, as given in (27)-(29). For this system, let an automatically scheduled LPV controller of the form

$$\dot{\zeta} = A_K(\hat{\theta}_L)\zeta + B_K(\hat{\theta}_L)y \quad (30)$$

$$u = C_K(\hat{\theta}_L)\zeta + D_K(\hat{\theta}_L)y \quad (31)$$

be designed through the procedure given in Theorem 1 where the parameter vector $\hat{\theta}_L$ is determined by the dynamics given in (10), and k is chosen such that

$$k > \frac{1}{2} (k_L + k_N + k_c)^2 + \gamma^2 . \quad (32)$$

where k_N , k_L and k_c are as given in (2), (7) and (12). Then:

1. The trajectories of the LPV system, with the parameter vector modified through the adaptation mechanism (10), will converge to the trajectories of the original nonlinear system (1).
2. The control signal u produced by the controller (30)-(31) will asymptotically stabilize the original nonlinear system (1).

Proof See Appendix A. □

Theorem 2 establishes the boundedness of all trajectories, the convergence of the LPV system trajectories to those of the nonlinear system and the stabilization of the nonlinear system with the designed LPV controller. However for proper operation one must implicitly assume that the parameter trajectories $\hat{\theta}_L(t)$ generated by the adaptation scheme (10) will be contained in the polytope Θ . The polytope Θ is typically selected by applying a wide range of signals with magnitudes and frequencies that are expected to occur during normal operation, and then observing the range in which the parameters vary. In practice, a properly selected polytope using this approach is usually enough to obtain an estimate of the range in which the parameter trajectories produced by the adaptation scheme will remain. Still, it may be of interest to establish certain criteria on the constants of the adaptation scheme that will theoretically ensure that the trajectories $\hat{\theta}_L(t)$ will remain in Θ . We shall not elaborate further on this issue at this point so as not to deviate from the main discussion, but we refer the interested reader to Appendix B, where sufficient conditions are established for the most common case for Θ , namely when Θ is a rectangular box.

6. Example

As an example we consider the following system

$$\dot{x}_1 = x_1 - 2x_2 + u + 3 \tanh(x_2) + \sin(x_1 u) - 1 + \sqrt{|x_1 x_2| + 1} \quad (33)$$

$$\dot{x}_2 = 3x_1 + 2x_2 + 4u + \sin(x_1 x_2) + u e^{-u^2} \quad (34)$$

which is of the form given in (1), and it can be shown that (2) is satisfied with Lipschitz constant $k_N = 9.1344$. The origin $(x_1, x_2) = (0, 0)$ is an unstable equilibrium under no forcing, and from non-zero initial conditions the trajectories diverge as shown in Figure 4.




Figure 4. Unforced response of the example system.

The goal is to find u so as to stabilize the system and drive the state $x := \text{col}(x_1, x_2)$ to zero. For this purpose, first an LPV system of the form (8) was obtained where

$$\hat{\theta}_L = \text{col}(\hat{a}_{11}, \hat{a}_{12}, \hat{a}_{21}, \hat{a}_{22}, \hat{b}_1, \hat{b}_2), \quad \Phi_L(x, u) = \begin{bmatrix} x_1 & x_2 & 0 & 0 & u & 0 \\ 0 & 0 & x_1 & x_2 & 0 & u \end{bmatrix} \quad (35)$$

and $\hat{\theta}_L$ is to be dictated by an adaptation scheme of the form (10). To determine an estimate for the range of values in which the parameter vector $\hat{\theta}_L$ will vary, a high number input signals of various types including ramp functions, sine functions, chirp functions, square waves and white noise were applied to the system. Observing the values assumed by the parameters under these excitation signals, the polytope Θ such that $\hat{\theta}_L \in \Theta$ was chosen to be the 6-dimensional box




Figure 5. Response of the example system in closed-loop system for twenty random values of the parameter vector and initial conditions, under a step disturbance.




Figure 6. States of the flow system and adapted states with the controller turned on at $t = 2$ seconds.

$$\Theta = \{0.32 < \hat{a}_{11} < 1.39, -2.51 < \hat{a}_{12} < -0.13, 1.88 < \hat{a}_{21} < 4.13, \\ -2.21 < \hat{a}_{22} < 3.54, 0.49 < \hat{b}_1 < 1.74, 2.57 < \hat{b}_2 < 5.04\} . \quad (36)$$

The constants of the adaptation mechanism (10) were selected as $k = 900$, $k_t = 100$, $k_d = 1$, $k_x = 20$ and $\theta_c = \text{col}(0.855, -1.320, 3.005, 0.665, 1.115, 3.805)$ based on the discussions in Section 5 (and also Appendix B).

The next step in the process is the design of the control law, which is based on the self-scheduled control technique outlined in Section 4. For the example problem there are six parameters and the parameter polytope Θ is a simple box in 6D space given in (36). The six LMIs (21) were set up for the system at hand, where the input filter (25)-(26) was selected simply as a first order band-pass Butterworth filter with $f_{\text{low}} = 0.01$ Hz and $f_{\text{high}} = 100$ Hz, which has an adequately large bandwidth and hence does not alter the system response

significantly. The LMIs were solved for X_{cl} and the control matrices A_{cl} , B_{cl} , C_{cl} and D_{cl} using the functions of the Robust Control Toolbox in MATLAB. The LMI formulation above was found to be feasible with a quadratic \mathcal{H}_∞ performance $\gamma = 0.0311$ from e to y for the closed loop system. This implies that the error cannot energize, i.e. disturb the output more than a limited amount. Figure 5 shows the closed loop system response under a step disturbance for twenty random values of the parameter vector $\hat{\theta}_L$ and initial conditions.

It can be seen that the controller is successful in stabilizing the system for all cases. During actual operation the parameter values will of course not be constants, but will be supplied in real time by the adaptation mechanism (10); however the results in Figure 5 serve as an initial test for the LPV controller.

The next step is to build, implement and test the full system shown in Figure 3. Figures 6-7 show the numerical simulation results for this configuration.




Figure 7. Parameter vector $\hat{\theta}_L$ with the controller turned on at $t = 2$ seconds.

For test purposes, the control action is set to be zero until $t = 2$ seconds, so that the system runs in open loop for this period. The controller is incorporated into the system by closing the loop at $t = 2$ seconds. It can be seen from Figure 6(b) that the controller achieves the desired stabilization of the LPV system and drives $\hat{x} \rightarrow 0$. Figure 6(c) shows the adaptation error $e = \hat{x} - x$, which seems to remain of the order 10^{-3} . The fact that $\hat{x} \rightarrow 0$ also implies that $x \rightarrow e$, and since error is very small, this practically means that the $x \rightarrow 0$ as well, as confirmed by Figure 6(a). Figure 7 shows the parameter vector $\hat{\theta}_L$ generated by the adaptation mechanism. It can be seen that there are considerable variations in the parameter trajectories throughout the process. Nevertheless, since these parameters are estimated internally by the adaptation mechanism and are available to the controller in real-time, the controller can utilize the current value of the parameter vector $\hat{\theta}_L(t)$ to automatically schedule its matrices and hence succeeds in the desired stabilization.

To further justify the design proposed in the paper and present a comparison, we also implement a controller based on a simple and standard method, namely a linearization-based LQR controller (see for instance [27]). For this purpose one considers only the linear part of the system (33)-(34), designs a control law of the form $u = -Kx$, where K is selected to minimize the objective function

$$J(u) = \int_0^\infty (x^T Q x + u^T R u) dt . \quad (37)$$

and then applies this control to the nonlinear system, hoping that the feedback will be able to take care of the neglected nonlinearities. However, for the problem at hand, despite numerous trials with many different values

for the weighing parameters Q and R , it was not possible to obtain an LQR controller that achieves stabilization of the original nonlinear system (33)-(34). The best results were obtained for $Q = I_2$ and $R = 100$, which result in the controller $u = -Kx$ with $K = [-0.1615 \ 1.5526]$. Figure 8 shows the result of the implementation of this control law on the original nonlinear system (33)-(34).




Figure 8. Response of the example system under LQR control, with the controller turned on at $t = 2$ seconds.

It can be seen that the control fails in achieving the desired stabilization and the system state x does not converge to the origin. As mentioned earlier, despite numerous trials it was not possible to find an linearization-based LQR controller that achieves $x \rightarrow 0$. Comparing the results with those from the LPV controller (Figure 6) it can be stated that the approach presented in the paper provides an improvement over a standard and common control design method, namely linearization-based LQR design approach.

7. Conclusions and future works

In this work a new method is proposed for building LPV system models through adaptation, for a class of nonlinear systems. Starting from the nonlinear system dynamics, an LPV model was built using the linear part, and its coefficients were considered as time-varying parameters. An adaptation scheme was constructed to control the variation of the parameters in time, with the goal of keeping the trajectories of the LPV system close to those of the original nonlinear system. Using the LPV model as a surrogate, a dynamical controller was built using robust self-scheduling methods for LPV systems, and it is shown that this controller would indeed stabilize the original nonlinear system. The results were illustrated on an example system and compared to a simple and standard alternative method, namely LQR control design based on linearization. It was seen that the controller design based on the LPV system outperforms the standard LQR controller, and is successful in achieving the desired stabilization.

The main contribution of the paper is to illustrate a novel approach for obtaining LPV models from a class of nonlinear systems through adaptation techniques. It is also shown how this model can be used to design an automatically-scheduled robust controller by utilizing results for LPV systems, and it is proved that this controller will indeed stabilize the original nonlinear system.

Future research directions include the expansion of the results to other classes of nonlinear systems,

estimating the parameter polytope in real-time, using different adaptation laws and control techniques, and application of the approach developed to physical problems experiments.

Acknowledgements

We would like to thank the libraries of TOBB Economics and Technology University for providing valuable resources that has made this work possible.

Appendix

A. Proof of Theorem 2

Since the controller is computed for system (27)-(29) using the approach outlined in Theorem 1, it holds that $\|\text{col}(x, u)\|_2 < \gamma\|e\|_2$, so the closed loop system is strictly dissipative with a supply rate

$$q(e, x, u) = \gamma^2\|e\|^2 - \|\text{col}(x, u)\|^2 \quad (38)$$

and storage function

$$V_a(x_a) = x_a^T X_{cl} x_a \quad (39)$$

That is,

$$\dot{V}_a \leq -\mu_a \|x_a\|^2 + q(e, a, u) \quad (40)$$

where $\mu_a \in \mathbb{R}_+$, X_{cl} is as given in the statement of Theorem 1, and $x_a := \text{col}(\hat{x}, \xi, \zeta)$ is the augmented state vector containing the states of the LPV system, the input filter and the controller. Note that

$$\underline{\alpha}_a(\|x_a\|) \leq V_a(x_a) \leq \bar{\alpha}_a(\|x_a\|) \quad (41)$$

where $\underline{\alpha}_a(r) := \lambda_{\min} r^2$, $\bar{\alpha}_a(r) := \lambda_{\max} r^2$ and λ_{\min} , λ_{\max} are the smallest and largest eigenvalues of X_{cl} . Define

$$V_t(e, \tilde{\theta}_L) := \frac{1}{2} e^T e + \frac{1}{2k_t} \tilde{\theta}_L^T \tilde{\theta}_L \quad (42)$$

and note that

$$\underline{\alpha}_t(\|\text{col}(e, \tilde{\theta}_L)\|) \leq V_t(e, \tilde{\theta}_L) \leq \bar{\alpha}_t(\|\text{col}(e, \tilde{\theta}_L)\|) \quad (43)$$

where $\underline{\alpha}_t(r) := k_2 r^2$, $\bar{\alpha}_t(r) := k_3 r^2$ and

$$k_2 := \min \left\{ \frac{1}{2}, \frac{1}{2k_t} \right\} \quad (44)$$

$$k_3 := \max \left\{ \frac{1}{2}, \frac{1}{2k_t} \right\}. \quad (45)$$

Consider now the entire system including the LPV plant, input filter, controller, adaptation law and the original nonlinear model, which is an autonomous system (Figure 3). Consider the state vector $x_e := \text{col}(\hat{x}, \xi, \zeta, e, \tilde{\theta}_L)$ for the entire system. Note that the state of the original nonlinear system is included implicitly since $x = \hat{x} - e$. Consider a candidate Lyapunov function

$$V(x_e) := V_a(\hat{x}, \xi, \zeta) + V_t(e, \tilde{\theta}_L) \quad (46)$$

where V_a is as defined in (39) and V_t is as in (42). Note that

$$\underline{\alpha}_e(\|x_e\|) \leq V(x_e) \leq \bar{\alpha}_e(\|x_e\|) \quad (47)$$

where $\underline{\alpha}_e(r) = k_4 r^2$, $\bar{\alpha}_e(r) = k_5 r^2$ and

$$k_4 := \min\{\lambda_{\min}, k_2\} \quad (48)$$

$$k_5 := \max\{\lambda_{\max}, k_3\} . \quad (49)$$

Differentiating (46) along trajectories yields

$$\dot{V}(x_e) = \dot{V}_a(\hat{x}, \xi, \zeta) + \dot{V}_t(e, \tilde{\theta}_L) \quad (50)$$

where we know that \dot{V}_a satisfies (40). To obtain a bound for \dot{V}_t , note from (42) that

$$\begin{aligned} \dot{V}_t &= e^T \dot{e} + \frac{1}{k_t} \tilde{\theta}_L^T \dot{\tilde{\theta}}_L \\ &= e^T \left(\Phi_L(x, u) \hat{\theta}_L - ke - \Phi_L(x, u) \theta_L - \Phi_N(x, u) \right) + \frac{1}{k_t} \tilde{\theta}_L^T \left(-k_t \Phi_L^T(x, u) e - k_t k_d \tilde{\theta}_L \right) \\ &= e^T \Phi_L(x, u) \hat{\theta}_L - k \|e\|^2 - e^T \Phi_L(x, u) \theta_L - e^T \Phi_N(x, u) - \tilde{\theta}_L^T \Phi_L^T(x, u) e - \tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, x, u) \\ &\leq -k \|e\|^2 + \|e\| \|\Phi_L(x, u) \theta_L\| + \|e\| \|\Phi_N(x, u)\| + \|e\| \|\Phi_L(x, u) \theta_c\| - \tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, x, u) \\ &\leq -k \|e\|^2 + \|e\| \|\text{col}(x, u)\| (k_L + k_N + k_c) - \tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, x, u) \\ &\leq -k \|e\|^2 + \frac{1}{2} \|e\|^2 (k_L + k_N + k_c)^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 - \tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, x, u) \end{aligned}$$

where we have used (2), (7), (12) and Young's inequality² as needed. Collecting similar terms and using the fact that $\tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, x, u) \geq 0$ yields

$$\dot{V}_t \leq - \left(k - \frac{1}{2} (k_L + k_N + k_c)^2 \right) \|e\|^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 - \tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, x, u) \quad (51)$$

$$\leq -(k - k_6) \|e\|^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 \quad (52)$$

where

$$k_6 := \frac{1}{2} (k_L + k_N + k_c)^2 \quad (53)$$

Substituting (40) and (52) into (50) yields

$$\begin{aligned} \dot{V}(x_e) &= \dot{V}_a(\hat{a}, \xi, \zeta) + \dot{V}_t(e, \tilde{\theta}_L) \\ &\leq -\mu \|x_a\|^2 + \gamma^2 \|e\|^2 - \|\text{col}(x, u)\|^2 - (k - k_6) \|e\|^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 \\ &\leq -\mu \|x_a\|^2 + (k - k_6 - \gamma^2) \|e\|^2 \end{aligned} \quad (54)$$

which is negative if (32) holds. Hence, all trajectories of the system are bounded, $x_a = \text{col}(\hat{x}, \xi, \zeta) \rightarrow 0$ and $e \rightarrow 0$. The fact that $e = \hat{x} - x \rightarrow 0$ implies $\hat{x} \rightarrow x$, which states that the trajectories of the LPV system, whose parameter variations are controlled by the designed adaptation mechanism, will converge to those of the original nonlinear system. The fact that $x_a \rightarrow 0$ implies $\hat{x} \rightarrow 0$, and since $\hat{x} \rightarrow x$, we have $x \rightarrow 0$, which states that the LPV control design based on the LPV plant is indeed successful in asymptotically stabilizing the origin of the nonlinear model. \square

²Let $x, y, \varepsilon \in \mathbb{R}_+$, then $xy \leq \frac{x^2}{2\varepsilon} + \frac{\varepsilon y^2}{2}$.

B. Conditions for $\hat{\theta}_L(t)$ to be confined to a box Θ

The theorem below states sufficient conditions for the parameter trajectories $\hat{\theta}_L(t)$ to eventually enter and remain in a desired polytope Θ , when Θ is a p -dimensional box.

Theorem 3 Consider the LPV plant augmented with an input filter, as given in (27)-(29). Assume that the polytope Θ in which $\hat{\theta}_L$ varies is a p -dimensional box defined by

$$\Theta = \{\theta \in \mathbb{R}^p : \underline{\theta}_i < \theta(i) < \bar{\theta}_i, \quad i = 1, \dots, p\} \quad (55)$$

where $\theta(i) \in \mathbb{R}$ denotes the i th component of θ , and $\bar{\theta}_i, \underline{\theta}_i$ are the minimum and maximum values allowed for the i th component of θ . For system (27)-(29), let an automatically scheduled LPV controller of the form (30)-(31) be designed through the procedure given in Theorem 1 where the parameter vector $\hat{\theta}_L$ is generated by the dynamics given in (10). Suppose that for the state vector x_e of this entire system, an upper bound is known on the size of the initial condition, i.e.

$$\|x_e(0)\| \leq k_{\text{IC}} \quad (56)$$

for some $k_{\text{IC}} \in \mathbb{R}_+$. Assume that the constant values for the adaptation scheme (10) are selected as follows

$$\theta_c = \frac{1}{2} \text{col}(\bar{\theta}_1 + \underline{\theta}_1, \bar{\theta}_2 + \underline{\theta}_2, \dots, \bar{\theta}_p + \underline{\theta}_p) \quad (57)$$

$$k_x < \frac{1}{2} \delta_\theta k_2 k_3^{-1} \sqrt{k_{10}^{-1} k_4 k_5^{-1} k_{\text{IC}}^{-1}} \quad (58)$$

$$k_d > \frac{1}{2k_x} \quad (59)$$

$$k > \max \left\{ k_6 + \gamma^2, k_6 + \frac{1}{2k_x} \right\} \quad (60)$$

where $k_{10} := \max\{1, \|C_u\|^2\}$, $\delta_\theta := \min_{i=1}^p \{\bar{\theta}_i - \underline{\theta}_i\}$ and k_2, k_3, k_4, k_5, k_6 are as given in (44), (45), (48), (49), (53). Then the parameter trajectory generated by (10) will eventually be confined to the p -dimensional box Θ given in (55).

Proof Note first that if (60) is satisfied, then (32) is also satisfied and hence the results of Theorem 2 are valid. We shall show that the system (9)-(10) is input-to-state stable (ISS), with $\text{col}(x, u)$ viewed as the input to the system. System (9)-(10) is ISS if and only if it has an ISS-Lyapunov function [25, 26]. Consider $V_t(e, \tilde{\theta}_L)$ given in (42) as a ISS-Lyapunov function candidate for the system. Differentiating V_t along trajectories of the system yields the expression in (51), from where it follows that

$$\dot{V}_t \leq -(k - k_6) \|e\|^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 - \tilde{\theta}_L^T \Psi(e, \tilde{\theta}_L, a, u). \quad (61)$$

Since (60) is satisfied, it holds that $k - k_6 > 0$. Also, if $\|\text{col}(e, \tilde{\theta}_L)\| \geq k_x \|\text{col}(x, u)\|$, then from (11) it follows that

$$\begin{aligned} \dot{V}_t &\leq -(k - k_6) \|e\|^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 - k_d \|\tilde{\theta}_L\|^2 \\ \dot{V}_t &\leq -k_8 \|\text{col}(e, \tilde{\theta}_L)\|^2 + \frac{1}{2} \|\text{col}(x, u)\|^2 \\ \dot{V}_t &\leq -k_8 \|\text{col}(e, \tilde{\theta}_L)\|^2 + \frac{1}{2k_x} \|\text{col}(e, \tilde{\theta}_L)\|^2 \\ \dot{V}_t &\leq -\left(k_8 - \frac{1}{2k_x}\right) \|\text{col}(e, \tilde{\theta}_L)\|^2 \\ \dot{V}_t &\leq -k_9 \|\text{col}(e, \tilde{\theta}_L)\|^2 \end{aligned} \tag{62}$$

where $k_8 = \min(k - k_6, k_d)$ and $k_9 := k_8 - (2k_x)^{-1}$. Note that $k_9 > 0$ as (59) and (60) hold. Then, if we define two \mathcal{K}_∞ functions as $\chi(r) := k_x r$, $\alpha(r) := k_9 r^2$, it is true that

$$\|\text{col}(e, \tilde{\theta}_L)\| \geq \chi(\|\text{col}(x, u)\|) \implies \dot{V}_t \leq -\alpha(\|\text{col}(e, \tilde{\theta}_L)\|) \tag{63}$$

which is the definition of V_t being an ISS-Lyapunov function. This shows that system (9)-(10) is ISS with $\text{col}(x, u)$ regarded as the input. From the definition of ISS, this implies that there exists a class \mathcal{KL} function β and a class \mathcal{K} function γ such that

$$\|\text{col}(e(t), \tilde{\theta}_L(t))\| \leq \max\left\{\beta(\text{col}(e(0), \tilde{\theta}_L(0)), t), \gamma(\|\text{col}(x, u)\|_\infty)\right\} \tag{64}$$

where γ can be shown to be of the form $\gamma = \underline{\alpha}_t^{-1} \circ \bar{\alpha}_t \circ \chi$.³ Since $\beta \in \mathcal{KL}$, it holds that as $t \rightarrow \infty$

$$\begin{aligned} \|\text{col}(e(t), \tilde{\theta}_L(t))\| &\leq \gamma(\|\text{col}(x, u)\|_\infty) \\ &\leq \underline{\alpha}_t^{-1} \circ \bar{\alpha}_t \circ \chi(\|\text{col}(x, u)\|_\infty) \\ &\leq k_2^{-1} k_3 k_x \|\text{col}(x, u)\|_\infty \end{aligned} \tag{65}$$

and since $\|\tilde{\theta}_L(t)\| \leq \|\text{col}(e(t), \tilde{\theta}_L(t))\|$ it follows that

$$\|\tilde{\theta}_L(t)\| \leq k_2^{-1} k_3 k_x \|\text{col}(x, u)\|_\infty . \tag{66}$$

Recall that we know $\|\text{col}(x, u)\|_\infty$ exists since the boundedness of all trajectories was established in Theorem 2. In fact, note that for the Lyapunov function V defined as in (46), it can be seen from (54) that $\dot{V} \leq 0$ along trajectories. Hence, using (47), we can write

$$\begin{aligned} \underline{\alpha}_e(\|x_e(t)\|) &\leq V(x_e(t)) \leq V(x_e(0)) \leq \bar{\alpha}_e(\|x_e(0)\|) \\ \|x_e(t)\|^2 &\leq k_4^{-1} k_5 \|x_e(0)\|^2 . \end{aligned} \tag{67}$$

Note that

$$\|\text{col}(x, u)\|^2 = \|\hat{x} - e\|^2 + \|u\|^2 \leq \|\hat{x}\|^2 + \|e\|^2 + \|C_u\|^2 \|\xi\|^2 \leq k_{10} \|\text{col}(\hat{x}, e, \xi)\|^2$$

³See for instance [26], page 22.

where $k_{10} := \max\{1, \|C_u\|^2\}$. Since $\|\text{col}(\hat{x}, e, \xi)\| \leq \|x_e\|$, we have

$$\|\text{col}(x, u)\|^2 \leq k_{10}\|x_e\|^2. \quad (68)$$

Then from (67) and (68) we obtain

$$\|\text{col}(x(t), u(t))\|^2 \leq k_{10}k_4^{-1}k_5\|x_e(0)\|^2$$

and thus

$$\|\text{col}(x, u)\|_\infty \leq \sqrt{k_{10}k_4^{-1}k_5}\|x_e(0)\|. \quad (69)$$

Substituting (69) into (66), and using (58) yields

$$\begin{aligned} \|\tilde{\theta}_L(t)\| &\leq k_2^{-1}k_3k_x\sqrt{k_{10}k_4^{-1}k_5}\|x_e(0)\| \\ \|\hat{\theta}_L(t) - \theta_c\| &\leq k_2^{-1}k_3k_x\sqrt{k_{10}k_4^{-1}k_5}k_{IC} \\ \|\hat{\theta}_L(t) - \theta_c\| &\leq \frac{\delta_\theta}{2}. \end{aligned} \quad (70)$$

Recall from (57) that θ_c is the centroid of the p -dimensional box Θ , and δ_θ is the length of its shortest side. Hence (70) states that the parameter trajectories $\hat{\theta}_L(t)$ will be contained in a p -dimensional sphere \mathcal{S} centered at the centroid of Θ , whose radius is shorter than half the length of the shortest side of Θ . Clearly $\mathcal{S} \subset \Theta$, hence the trajectories will be contained in Θ , i.e. $\hat{\theta}_L(t) \in \Theta$. \square

References

- [1] A. Packard. Gain scheduling via linear fractional transformations. *Systems & Control Letters*, 22(2):79–92, 1994.
- [2] R. Murray-Smith and T.A. Johansen. *Multiple Model Approaches to Modelling and Control*. CRC Press, 1997.
- [3] J.S. Shamma and M. Athans. Gain scheduling: potential hazards and possible remedies. *Control Systems Magazine, IEEE*, 12(3):101–107, 1992.
- [4] W.J. Rugh and J.S. Shamma. A survey of research on gain-scheduling. *Automatica*, 36(10):1401–1425, 2000.
- [5] D.J. Leith and W.E. Leithead. Survey of gain-scheduling analysis and design. *International Journal of Control*, 73(11):1001–1025, 2000.
- [6] P. Apkarian, P. Gahinet, and G. Becker. Self-Scheduled H-Infinity Control of Linear Parameter-Varying Systems—a Design Example. *Automatica*, 31(9):1251–1261, 1995.
- [7] G. Becker and A. Packard. Robust performance of linear parametrically varying systems using parametrically-dependent linear feedback. *Systems & Control Letters*, 23(3):205–215, 1994.
- [8] J.Y. Shin, G.J. Balas, and M.A. Kaya. Blending Methodology of Linear Parameter Varying Control Synthesis of F-16 Aircraft System. *Journal of Guidance, Control and Dynamics*, 25(6):1040–1048, 2002.
- [9] A. Fujimori and L. Ljung. Model Identification of Linear Parameter Varying Aircraft Systems. *Proceedings of the Institution of Mechanical Engineers, Part G: Journal of Aerospace Engineering*, 220(4):337–346, 2006.

- [10] J.S. Shamma and J.R. Cloutier. Gain-Scheduled Missile Autopilot Design Using Linear Parameter Varying Transformations. *Journal of Guidance, Control, and Dynamics*, 16(2):256–263, 1993.
- [11] P. Hingwe, H.S. Tan, A.K. Packard, M. Tomizuka, P. California, and CA Richmond. Linear parameter varying controller for automated lane guidance: experimental study on tractor-trailers. *Control Systems Technology, IEEE Transactions on*, 10(6):793–806, 2002.
- [12] B. Bodenheimer, P. Bendotti, and M. Kantner. Linear parameter-varying control of a ducted fan engine. *International Journal of Robust and Nonlinear Control*, 6(910):1023–1044, 1996.
- [13] G.J. Balas. Linear, parameter-varying control and its application to a turbofan engine. *International Journal of Robust and Nonlinear Control*, 12(9):763–796, 2002.
- [14] M.V. Kothare, B. Mettler, M. Morari, P. Bendotti, and C.M. Falinower. Linear parameter varying model predictive contr for steam generator level control. *Computers and Chemical Engineering*, 21:861–866, 1997.
- [15] K. Fitzpatrick, Y. Feng, R. Lind, and A.J. Kurdila. Flow Control in a Driven Cavity Incorporating Excitation Phase Differential. *Journal of Guidance, Control, and Dynamics*, 28(1), 2005.
- [16] Y. Feng, A.J. Kurdila, R. Lind, and D.W. Mikolaitis. Linear Parameter-Varying Flow Control for a Driven Cavity using Reduced-Order Models. In *AIAA Guidance, Navigation and Control Conference*, pages 2003–5351, 2003.
- [17] L.H. Lee and K. Poolla. Identification of Linear Parameter-Varying Systems Using Nonlinear Programming. *Journal of Dynamic Systems, Measurement, and Control*, 121:71, 1999.
- [18] V. Verdult and M. Verhaegen. Subspace identification of multivariable linear parameter-varying systems. *Automatica*, 38(5):805–814, 2002.
- [19] V. Verdult and M. Verhaegen. Kernel methods for subspace identification of multivariable LPV and bilinear systems. *Automatica*, 41(9):1557–1565, 2005.
- [20] B. Bamieh and L. Giarre. Identification of linear parameter varying models. *International Journal of Robust and Nonlinear Control*, 12(9):841–853, 2002.
- [21] M. Krstic, P.V. Kokotovic, and I. Kanellakopoulos. *Nonlinear and Adaptive Control Design*. John Wiley & Sons, Inc. New York, NY, USA, 1995.
- [22] K.J. Astrom and B. Wittenmark. *Adaptive Control*. Addison-Wesley Longman Publishing Co., Inc. Boston, MA, USA, 1994.
- [23] C.P.A. Ioannou and J. Sun. *Robust Adaptive Control*. Prentice-Hall, Upper Saddle River, NJ, 1996.
- [24] H.K. Khalil. *Nonlinear Systems*. Prentice Hall,, Upper Saddle River, NJ :, c1996.
- [25] E.D. Sontag. *Mathematical Control Theory: Deterministic Finite Dimensional Systems*. Springer, 1998.
- [26] A. Isidori. *Nonlinear Control Systems II*. Springer, London, UK, 1999.
- [27] C.T. Chen. *Linear System Theory and Design*. Saunders College Publishing Philadelphia, PA, USA, 1984.